



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay
Jim Doyle, Governor
Richard J. Leinenkugel, Secretary

April 6, 2009

JOHNSON DIVERSEY
DISPENSING TECHNOLOGY
CHRIS LANG
8310 16TH ST
STURTEVANT WI 53177

JOHNSON DIVERSEY
DISPENSING TECHNOLOGY
DAN GILLESPIE
8310 16TH ST
STURTEVANT WI 53177

Re: Description: PROPORTIONER
Manufacturer: JOHNSON DIVERSEY
Product Name: BUTCHER RTD
Model Number(s): RTD
Product File No: 20090147

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.11 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2014.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product must be installed with a S.C. Johnson & Son, Inc., Flo-Thru device permanently connected to the inlet of the hose serving this product when this product is not served by a separate water supply connection.

This approval supersedes the approval issued on March 25, 2004 under product file number 20040130.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040130.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov